



An ISO 9001:2008 Company

Anjani Portland Cement Limited

(A Subsidiary of Chettinad Cement Corporation Limited)

Ordinary Portland Cement 43 Grade Test Certificate

Ref.: APCL/QUAS/TEST/ W.No:07

Date of Despatch:14.02.16

Particulars	Test Result	Requirement as per IS 8112 : 2013
CHEMICAL (As per IS: 4032-1985)		
<ul style="list-style-type: none"> • LOI (%) • I.R. (%) • SO₃ (%) • MgO (%) • Chloride (%) • L.S.F. • A/F 	<p>1.89</p> <p>3.23</p> <p>2.32</p> <p>0.75</p> <p>0.02</p> <p>0.87</p> <p>1.25</p>	<p>5.0 Max.</p> <p>4.0 Max.</p> <p>3.5 Max.</p> <p>6.0 Max.</p> <p>0.10 Max.</p> <p>0.66 to 1.02</p> <p>0.66 Min</p>
PHYSICAL (As per IS: 4031-1988)		
<ul style="list-style-type: none"> • Spec.Surface (M²/Kg) • SOUNDNESS: • Le-Chatlier (mm) • Autoclave (%) • SETTING TIME (Minutes) • Initial • Final • COMPRESSIVE STRENGTH (M Pa) • 3 Days • 7 Days • 28 Days 	<p>275</p> <p>1</p> <p>0.09</p> <p>170</p> <p>280</p> <p>33.2</p> <p>44.1</p> <p>52.9</p>	<p>225 Min.</p> <p>10 Max.</p> <p>0.8 Max.</p> <p>30 Min.</p> <p>600 Min.</p> <p>23 Min.</p> <p>33 Min.</p> <p>43 Min.</p> <p>58 Max. }</p>

Certified that the cement complies
With IS 8112 : 2013

Manager (QUAS)

A.V.P. (Ope & Quas)

Works : Anjanipuram, Gudimalkapuram(V), Mellacheruvu(M), Nalgonda (Dist), Telangana State – 508246

Head Office : # 6-3-553, Quena Square – 4th floor ,E3 & E4 ,Erramanzil , Somajiguda , Hyderabad -500 082,Telangana,INDIA.