



An ISO 9001:2008 Company

Anjani Portland Cement Limited

(A Subsidiary of Chettinad Cement Corporation Limited)

Ordinary Portland Cement 43 Grade Test Certificate

Ref.: APCL/QUAS/TEST/ W.No:06

Date of Despatch:06.02.16

Particulars	Test Result	Requirement as per IS 8112 : 2013
CHEMICAL (As per IS: 4032-1985)		
<ul style="list-style-type: none">• LOI (%)• I.R. (%)• SO₃ (%)• MgO (%)• Chloride (%)• L.S.F.• A/F	<p>1.99 3.11 2.38 0.84 0.02 0.87 1.26</p>	<p>5.0 Max. 4.0 Max. 3.5 Max. 6.0 Max. 0.10 Max. 0.66 to 1.02 0.66 Min</p>
PHYSICAL (As per IS: 4031-1988)		
<ul style="list-style-type: none">• Spec.Surface (M²/Kg)• SOUNDNESS:<ul style="list-style-type: none">• Le-Chatlier (mm)• Autoclave (%)• SETTING TIME (Minutes)<ul style="list-style-type: none">• Initial• Final• COMPRESSIVE STRENGTH (M Pa)<ul style="list-style-type: none">• 3 Days• 7 Days• 28 Days	<p>274 01 0.03 170 310 32.2 42.9 U.T.</p>	<p>225 Min. 10 Max. 0.8 Max. 30 Min. 600 Min. 23 Min. 33 Min. 43 Min. 58 Max. }</p>

Certified that the cement complies
With IS 8112 : 2013

Manager (QUAS)

A.V.P. (Ope & Quas)

Works : Anjanipuram, Gudimalkapuram(V), Mellacheruvu(M), Nalgonda (Dist), Telangana State – 508246

Head Office : # 6-3-553, Quena Square – 4th floor ,E3 & E4 ,Erramanzil , Somajiguda , Hyderabad -500 082,Telangana,INDIA.