



An ISO 9001:2015 Company

Anjani Portland Cement Limited

(A Subsidiary of Chettinad Cement Corporation Pvt. Limited)

Ordinary Portland Cement 53 Grade Test Certificate

Ref.: APCL/QUAS/TEST/ W.No:43

Date of Despatch: 22.10.18

Particulars	Test Result	Requirement as per IS 269 : 2015
CHEMICAL (As per IS: 4032-1985)		
• LOI (%)	3.34	4.0 Max.
• I.R. (%)	3.28	5.0 Max.
• SO ₃ (%)	2.36	3.5 Max.
• MgO (%)	0.85	6.0 Max.
• Chloride (%)	0.02	0.10 Max.
• L.S.F.	0.85	0.80 to 1.02
• A/F	1.24	0.66 Min
PHYSICAL (As per IS: 4031-1988)		
• Spec.Surface (M ² /Kg)	300	225 Min.
SOUNDNESS:		
• Le-Chatlier (mm)	01	10 Max.
• Autoclave (%)	0.048	0.8 Max.
SETTING TIME (Minutes)		
• Initial	145	30 Min.
• Final	250	600 Max.
COMPRESSIVE STRENGTH (M Pa)		
• 3 Days	37.3	27 Min.
• 7 Days	46.8	37 Min.
• 28 Days	59.9	53 Min.

Certified that the cement complies
With IS 269 : 2015

Sr.Manager (QUAS)

Joint President(Works)

Works : Anjanipuram, Gudimalkapuram(P), Chinthalapalem(V&M), Suryapeta (Dist), Telangana State – 508246

Head Office : # 6-3-553, Quena Square – 4th floor ,E3 & E4 ,Erramanzil , Somajiguda , , Hyderabad -500 082,Telangana,INDIA.