



An ISO 9001:2008 Company

# Anjani Portland Cement Limited

( A Subsidiary of Chettinad Cement Corporation Limited )

## PPC Test Certificate

Ref.: APCL/QUAS/TEST / W.No:13

Date of Despatch: 26.03.17

Particulars	Test Result	Requirement as per IS 1489(Part-1) : 1991
<b>CHEMICAL ( As per IS: 4032-1985)</b>		
<ul style="list-style-type: none"><li>• LOI ( % )</li><li>• I.R. ( % )</li><li>• SO<sub>3</sub> ( % )</li><li>• MgO ( % )</li><li>• Chloride ( % )</li></ul>	<p>2.94</p> <p>30.96</p> <p>2.32</p> <p>0.76</p> <p>0.02</p>	<p>5.0 Max.</p> <p><math>X+4(100-x)</math></p> <p>100</p> <p>(Where X is Declared % of Fly ash)</p> <p>3.0 Max.</p> <p>6.0 Max.</p> <p>0.10 Max.</p>
<b>PHYSICAL (As per IS: 4031-1988)</b>		
<ul style="list-style-type: none"><li>• Spec.Surface (M<sup>2</sup>/Kg)</li><li>• SOUNDNESS:</li><li>• Le-Chatlier (mm)</li><li>• Autoclave (%)</li><li>• SETTING TIME (Minutes)</li><li>• Initial</li><li>• Final</li><li>• COMPRESSIVE STRENGTH (M Pa)</li><li>• 3 Days</li><li>• 7 Days</li><li>• 28 Days</li></ul>	<p>345</p> <p>01</p> <p>0.058</p> <p>150</p> <p>260</p> <p>24.2</p> <p>34.0</p> <p>45.7</p>	<p>300 Min.</p> <p>10 Max.</p> <p>0.8 Max.</p> <p>30 Min.</p> <p>600 Min.</p> <p>16 Min.</p> <p>22 Min.</p> <p>33 Min.</p>

Certified that the cement complies  
With IS 1489 (Part - 1) : 1991

Manager (QUAS)

Vice President (Works)

Works : Anjanipuram, Gudimalkapuram(V), Mellacheruvu(M), Nalgonda (Dist), Telangana State – 508246  
Head Office : # 6-3-553, Quena Square – 4<sup>th</sup> floor ,E3 & E4 ,Erramanzil , Somajiguda , , Hyderabad -500 082,Telangana,INDIA.