



An ISO 9001:2015 Company

Anjani Portland Cement Limited

(A Subsidiary of Chettinad Cement Corporation Pvt. Limited)

Ordinary Portland Cement 43 Grade Test Certificate

Ref.: APCL/QUAS/TEST/ W.No:49

Date of Despatch: 03.12.2025

QUAS/F - 26

| Particulars | Test Result | Requirement as per IS 269 : 2015 |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------|
| CHEMICAL (As per IS: 4032-1985) | | |
| <ul style="list-style-type: none">• LOI (%)• I.R. (%)• SO₃ (%)• MgO (%)• Chloride (%)• L.S.F.• A/F | <p>3.42 1.84 2.24 1.16 0.03 0.89 1.35</p> | <p>5.0 Max. 5.0 Max. 3.5 Max. 6.0 Max. 0.10 Max. 0.66 to 1.02 0.66 Min</p> |
| PHYSICAL (As per IS: 4031-1988) | | |
| <ul style="list-style-type: none">• NC (%)• Fineness (M²/Kg)• SOUNDNESS:• Le-Chatlier (mm)• Autoclave (%)• SETTING TIME (Minutes)• Initial• Final• COMPRESSIVE STRENGTH (M Pa)• 3 Days• 7 Days• 28 Days | <p>30.5 279 01 0.028 140 240 33.6 43.6 U.T</p> | <p>225 Min. 10 Max. 0.8 Max. 30 Min. 600 Max. 23 Min. 33 Min. 43 Min. 58 Max. }</p> |

Certified that the cement complies
With IS 269 : 2015

G.M (QUAS & Ope.)

Unit Head

Works : Anjanipuram, Gudimalkapuram(P), Chinthalapalem(V&M), Suryapeta (Dist), Telangana State – 508246

Head Office : # 6-3-553, Quena Square – 4th floor ,E3 & E4 ,Erramanzil , Somajiguda , , Hyderabad -500 082,Telangana,INDIA.

Marketed by: Chettinad Cement Corporation Private Limited