



An ISO 9001:2008 Company

# Anjani Portland Cement Limited

(A Subsidiary of Chettinad Cement Corporation Pvt. Limited)

## Ordinary Portland Cement 43 Grade Test Certificate

Ref.: APCL/QUAS/TEST/ W.No:30

Date of Despatch: 23.07.18

Particulars	Test Result	Requirement as per IS 269 : 2015
<b>CHEMICAL ( As per IS: 4032-1985)</b>		
<ul style="list-style-type: none"><li>LOI ( % )</li><li>I.R. ( % )</li><li>SO<sub>3</sub> ( % )</li><li>MgO ( % )</li><li>Chloride ( % )</li><li>L.S.F.</li><li>A/F</li></ul>	<p>2.94 3.26 2.38 0.95 0.02 0.87 1.19</p>	<p>5.0 Max. 5.0 Max. 3.5 Max. 6.0 Max. 0.10 Max. 0.66 to 1.02 0.66 Min</p>
<b>PHYSICAL (As per IS: 4031-1988)</b>		
<ul style="list-style-type: none"><li>Spec.Surface (M<sup>2</sup>/Kg)</li><li>SOUNDNESS:<ul style="list-style-type: none"><li>Le-Chatlier (mm)</li><li>Autoclave (%)</li></ul></li><li>SETTING TIME (Minutes)<ul style="list-style-type: none"><li>Initial</li><li>Final</li></ul></li><li>COMPRESSIVE STRENGTH (M Pa)<ul style="list-style-type: none"><li>3 Days</li><li>7 Days</li><li>28 Days</li></ul></li></ul>	<p>277 01 0.044 145 250 33.3 43.4 U.T.</p>	<p>225 Min. 10 Max. 0.8 Max. 30 Min. 600 Max. 23 Min. 33 Min. 43 Min. 58 Max. }</p>

Certified that the cement complies  
With IS 269: 2015

Sr.Manager (QUAS )

Sr.Vice President (Works)

Works : Anjanipuram, Gudimalkapuram(P), Chinthalapalem(V&M), Suryapeta (Dist), Telangana State – 508246

Head Office : # 6-3-553, Quena Square – 4<sup>th</sup> floor ,E3 & E4 ,Erramanzil , Somajiguda , , Hyderabad -500 082,Telangana,INDIA.