



An ISO 9001:2015 Company

Anjani Portland Cement Limited

(A Subsidiary of Chettinad Cement Corporation Pvt. Limited)

Ordinary Portland Cement 53 Grade Test Certificate

Ref.: APCL/QUAS/TEST/ W.No:45

Date of Despatch: 04.11.2020

Particulars	Test Result	Requirement as per IS 269 : 2015
CHEMICAL (As per IS: 4032-1985)		
<ul style="list-style-type: none">• LOI (%)• I.R. (%)• SO₃ (%)• MgO (%)• Chloride (%)• L.S.F.• A/F	<p>3.37 3.38 2.30 1.05 0.03 0.85 1.21</p>	<p>4.0 Max. 5.0 Max. 3.5 Max. 6.0 Max. 0.10 Max. 0.80 to 1.02 0.66 Min</p>
PHYSICAL (As per IS: 4031-1988)		
<ul style="list-style-type: none">• Fineness (M²/Kg)• SOUNDNESS:<ul style="list-style-type: none">• Le-Chatlier (mm)• Autoclave (%)• SETTING TIME (Minutes)<ul style="list-style-type: none">• Initial• Final• COMPRESSIVE STRENGTH (M Pa)<ul style="list-style-type: none">• 3 Days• 7 Days• 28 Days	<p>296 01 0.026 150 250 37.5 47.5 60.9</p>	<p>225 Min. 10 Max. 0.8 Max. 30 Min. 600 Max. 27 Min. 37 Min. 53 Min.</p>

Certified that the cement complies
With IS 269 : 2015

Sr.Manager (QUAS)

Joint President(Works)

Works : Anjanipuram, Gudimalkapuram(P), Chinthalapalem(V&M), Suryapeta (Dist), Telangana State – 508246

Head Office : # 6-3-553, Quena Square – 4th floor ,E3 & E4 ,Erramanzil , Somajiguda , , Hyderabad -500 082,Telangana,INDIA.