



An ISO 9001:2015 Company

Anjani Portland Cement Limited

(A Subsidiary of Chettinad Cement Corporation Pvt Limited)

PPC Test Certificate

Ref.: APCL/QUAS/TEST / W.No:10

Date of Despatch: 05.03.2021

Particulars	Test Result	Requirement as per IS 1489(Part-1) : 2015
CHEMICAL (As per IS: 4032-1985)		
<ul style="list-style-type: none">LOI (%)I.R. (%)SO₃ (%)MgO (%)Chloride (%)Declared percentage of Pozzolana (%)	<p>3.27 31.89 2.30 0.94 0.04 33.0</p>	<p>5.0 Max. Max:$X+4(100-X)$ 100 Min : 0.60 x X (Where X is Declared % of Fly ash) 3.0 Max. 6.0 Max. 0.10 Max. Min-15%,Max-35%</p>
PHYSICAL (As per IS: 4031-1988)		
<ul style="list-style-type: none">Fineness (M²/Kg)SOUNDNESS:<ul style="list-style-type: none">Le-Chatlier (mm)Autoclave (%)SETTING TIME (Minutes)<ul style="list-style-type: none">InitialFinalCOMPRESSIVE STRENGTH (M Pa)<ul style="list-style-type: none">3 Days7 Days28 Days	<p>353 01 0.012 150 250 22.9 32.8 46.5</p>	<p>300 Min. 10 Max. 0.8 Max. 30 Min. 600 Min. 16 Min. 22 Min. 33 Min.</p>

Certified that the cement complies
With IS 1489 (Part - 1) : 2015

Sr.Manager (QUAS)

Joint President (Works)

Works : Anjanipuram, Gudimalkapuram(P), Cinthalapalem(V&M), Suryapeta (Dist), Telangana State – 508246
Head Office : # 6-3-553, Quena Square – 4th floor ,E3 & E4 ,Erramanzil , Somajiguda , Hyderabad -500 082,Telangana,INDIA.